



Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Pratapgarh u.p
Address- District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Sukhpalnagar, Pratapgarh -230002

Report No:	UPJN(R)/PBH/DL/6334	Issue Date:	06/06/2026		
Remark	-			Page No	1/1
Contact Person:	DIGVIJAY SINGH	Address:	UPJN(R) District Lab pratapgarh	Mob:	916904846 6

Customer Details

Office Name and Address	BL Sudhita International school ,Village-Saherua,Post-Vishwanathganj,Block-Mandhata,Distt-Pratapgarh
Ref Letter No & Date	27/05/2026

Basic details of sample

District	Pratapgarh	Block	Mandhata
Gram Panchayat	Saherua	Village	Saherua
Habitation	-	Location	BL Sudhita International school campus
Water Source	Submersible	Sample No.	S-6334
Quantity of Sample	1 litre	Date of Collection	27/05/26
Receiving Date	27/05/26	S. Collector	Shri Sanjay Srivastava
Sample Depositor	Shri Adarsh Jaiswal	Sampling Method	As per IS 17614 par:2021
Analysis Start Date	30/05/26	Analysis Completion Date:	30/05/26
Temperature : 28 C		Humidity: 50%	


Technical Data of Analysis

	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit		
1	2	3	4	6	
1	pH	7.42	6.5-8.5	IS3025 (Part 11):2022(Electrometric method)	
2	Turbidity NTU	0.90	1	IS 3025 (Part 10):2023	
3	TDS mg/L	204	500	IS 3025 (Part 16):2023	
4	Fluoride mg/L	0.495	1	IS 3025 (Part 60):2023 (Electrode method)	
5	Total Hardness mg/L	106.59	200	IS 3025 (Part 21):2023	
6	Total Alkalinity mg/L	172	200	IS 3025 (Part 23):2023	
7	Chloride mg/L	163.83	250	IS 3025 (Part 32):2025	
8	Calcium(as Ca) mg/L	16.03	75	IS 3025 (Part 40):2024	
9	Magnesium (asMg) mg/L	16.52	30	IS 3025 (Part 46):2023	
10	Colour(HU)	1	5	IS 3025 (Part 4):2021 (Visual comparison method)	
11	Odour	Agreeable	Agreeable / Disagreeable	IS 3025 (Part 8):2023	
12	Taste	Agreeable	Agreeable / Disagreeable	IS 3025 (Part 5):2018	

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests report.
5. Source is Not Verified by the Laboratory.

Prepared By-



End of Report